

# SISTEMA SANCAD - PLANILHA DE DADOS FINAIS

## IGUABA\_RJ

### BAIRRO CIDADE NOVA

### PROJETO DE REDE COLETORA DE ESGOTOS

22/01/2021

Trecho	PVM	PVJ	Comp (m)	CTM (m)	CTJ (m)	CCM (m)	CCJ (m)	PRFM (m)	PRFJ (m)	Diam (mm)	Decl (m/m)	Q Real Ini (l/s)	Q Real Fim (l/s)	Veloc Ini (m/s)	Veloc Fim (m/s)	Veloc Crit (m/s)	Trativa (Pa)	H/D Ini	H/D Fim	Observ.
009-001	PV10.771	PV10.7.7	32.00	1.760	2.560	0.710	0.560	1.050	2.000	150	0.00460	0.135	0.405	0.50	0.50	2.67	0.87	0.23	0.23	DG 0.050
008-001	PV10.752	PV10.7.5	65.00	9.190	8.690	8.140	7.640	1.050	1.050	150	0.00769	0.274	0.824	0.60	0.60	2.52	1.30	0.20	0.20	TQ 2.660
007-001	PV10.751	PV10.7.5	37.00	10.440	8.690	9.390	7.640	1.050	1.050	150	0.04730	0.156	0.469	1.14	1.14	2.06	5.34	0.13	0.13	TQ 2.660
006-001	PV10.7.1	PV10.7.2	73.00	7.620	6.630	6.570	5.580	1.050	1.050	150	0.01356	0.308	0.925	0.74	0.74	2.37	2.02	0.17	0.17	
006-002	PV10.7.2	PV10.7.3	14.00	6.630	6.550	5.580	5.500	1.050	1.050	150	0.00571	0.367	1.102	0.54	0.54	2.60	1.03	0.21	0.21	
006-003	PV10.7.3	PV10.7.4	35.00	6.550	6.450	5.500	5.340	1.050	1.110	150	0.00460	0.515	1.546	0.50	0.51	2.68	0.87	0.23	0.23	
006-004	PV10.7.4	PV10.7.5	78.00	6.450	8.690	5.340	4.980	1.110	3.710	150	0.00460	0.844	2.534	0.50	0.58	2.99	0.87	0.23	0.29	
006-005	PV10.7.5	PV10.7.6	49.00	8.690	6.030	4.980	4.760	3.710	1.280	150	0.00460	1.481	4.447	0.50	0.68	3.36	0.87	0.23	0.40	
006-006	PV10.7.6	PV10.7.7	32.00	6.030	2.560	4.760	1.510	1.280	1.050	150	0.10141	1.616	4.853	1.52	2.11	2.46	9.97	0.11	0.19	TQ 0.997
006-007	PV10.7.7	PV10.7	57.00	2.560	1.350	0.510	0.250	2.050	1.100	150	0.00461	1.992	5.980	0.55	0.74	3.56	0.99	0.26	0.47	TQ 0.681
005-001	PV10.6.1	PV10.6	73.00	2.260	1.490	1.210	0.440	1.050	1.050	150	0.01055	0.308	0.925	0.67	0.67	2.43	1.66	0.18	0.18	DG 0.545
004-001	PV10.5.1	PV10.5.2	64.00	8.990	5.950	7.940	4.900	1.050	1.050	150	0.04750	0.270	0.811	1.14	1.14	2.06	5.35	0.13	0.13	
004-002	PV10.5.2	PV10.5.3	64.00	5.950	3.150	4.900	2.100	1.050	1.050	150	0.04375	0.540	1.622	1.11	1.14	2.11	5.02	0.13	0.14	
004-003	PV10.5.3	PV10.5	64.00	3.150	1.500	2.100	0.450	1.050	1.050	150	0.02578	0.810	2.433	0.92	1.06	2.45	3.33	0.15	0.19	DG 0.294
003-001	PV10.4.1	PV10.4	49.00	1.620	1.460	0.570	0.350	1.050	1.120	150	0.00460	0.207	0.621	0.50	0.50	2.67	0.87	0.23	0.23	
002-001	PV10.1	PV10.2	50.00	9.420	5.250	8.370	4.200	1.050	1.050	150	0.08340	0.211	0.634	1.39	1.39	1.93	8.28	0.11	0.11	
002-002	PV10.2	PV10.3	57.00	5.250	2.830	4.200	1.780	1.050	1.050	150	0.04246	0.452	1.356	1.10	1.10	2.08	4.91	0.13	0.13	
002-003	PV10.3	PV10.4	57.00	2.830	1.460	1.780	0.410	1.050	1.050	150	0.02404	0.692	2.078	0.90	0.99	2.39	3.16	0.15	0.18	DG 0.065
002-004	PV10.4	PV10.5	41.00	1.460	1.500	0.350	0.160	1.120	1.340	150	0.00461	1.072	3.218	0.50	0.62	3.14	0.87	0.23	0.33	
002-005	PV10.5	PV10.6	57.00	1.500	1.490	0.160	-0.110	1.340	1.600	150	0.00460	2.123	6.373	0.55	0.75	3.60	1.01	0.27	0.48	
002-006	PV10.6	PV10.7	71.00	1.490	1.350	-0.110	-0.430	1.600	1.780	150	0.00460	2.730	8.198	0.60	0.80	3.77	1.13	0.31	0.56	
002-007	PV10.7	PV10.8	43.00	1.350	1.250	-0.430	-0.720	1.780	1.970	150	0.00667	4.904	14.723	0.80	1.04	4.00	1.94	0.38	0.75	DG 0.050
002-008	PV10.8	PV010	44.00	1.250	1.040	-0.770	-0.970	2.020	2.010	200	0.00460	5.089	15.280	0.69	0.93	4.25	1.41	0.28	0.52	DG 0.527
001-001	PV001	PV002	33.00	2.040	1.830	0.990	0.780	1.050	1.050	150	0.00636	0.139	0.418	0.56	0.56	2.57	1.12	0.21	0.21	

Trecho	PVM	PVJ	Comp (m)	CTM (m)	CTJ (m)	CCM (m)	CCJ (m)	PRFM (m)	PRFJ (m)	Diam (mm)	Decl (m/m)	Q Real Ini (l/s)	Q Real Fim (l/s)	Veloc Ini (m/s)	Veloc Fim (m/s)	Veloc Crit (m/s)	Trativa (Pa)	H/D Ini	H/D Fim	Observ.
001-002	PV002	PV003	38.00	1.830	1.450	0.780	0.400	1.050	1.050	150	0.00992	0.300	0.900	0.66	0.66	2.45	1.59	0.19	0.19	
001-003	PV003	PV004	75.00	1.450	1.460	0.400	0.060	1.050	1.410	150	0.00460	0.616	1.850	0.50	0.53	2.79	0.87	0.23	0.25	
001-004	PV004	PV005	75.00	1.460	1.340	0.060	-0.290	1.410	1.630	150	0.00460	0.933	2.800	0.50	0.60	3.05	0.87	0.23	0.31	
001-005	PV005	PV006	75.00	1.340	1.280	-0.290	-0.630	1.630	1.910	150	0.00460	1.249	3.751	0.50	0.65	3.24	0.87	0.23	0.36	
001-006	PV006	PV007	51.00	1.280	1.350	-0.630	-0.870	1.910	2.220	150	0.00460	1.464	4.397	0.50	0.68	3.35	0.87	0.23	0.39	
001-007	PV007	PV008	35.00	1.350	1.420	-0.870	-1.030	2.220	2.450	150	0.00460	1.612	4.840	0.51	0.70	3.41	0.94	0.23	0.42	
001-008	PV008	PV009	45.00	1.420	1.330	-1.030	-1.230	2.450	2.560	150	0.00460	1.802	5.410	0.53	0.72	3.49	0.94	0.25	0.44	
001-009	PV009	PV010	45.00	1.330	1.040	-1.230	-1.440	2.560	2.480	150	0.00460	1.992	5.981	0.54	0.74	3.56	0.98	0.26	0.47	DG 0.058
001-010	PV010	FIM	7.00	1.040	1.060	-1.500	-1.530	2.540	2.590	200	0.00460	7.111	21.350	0.76	1.01	4.50	1.63	0.34	0.64	FIM